



Certificate

2206-1048C; 2206-1048D

Eccua Pro OÜ

Angerja tee 40, 76911 Hüüru Küla, Saue Vald, Harjumaa, Estonia

EN858-1, chapter 8.3.3

Separator systems for light liquids

Light liquid separators

Test report PIA2022-AB-2206-1048C/D

Evaluation of the nominal size and class following EN858-1

Nominal size	Separator system	Average effluent concentration	Class
NS6	Oilseparator 1-class (with HD Q-PAC®)	< 5 mg/l	1
NS6	Oilseparator 1-class (with EC filter)	< 5 mg/l	1

Tested by:

PIA – Prüfinstitut für Abwassertechnik GmbH

(PIA GmbH)

Hergenrather Weg 30

52074 Aachen, Germany

This document replaces neither the declaration of performance nor the CE marking.



Daniela Schmitz November 2022



Notified Body
No.: 1739

