





EN 858-1



I'd like to order

I'd like a quote

Mark the installation depth of the tank h (depth from the ground to the bottom of the inlet pipe in mm) h =

Notes (name of project or address, special need etz):

No	NAME	MATERIAL	SIZE	Qn/pcs				
1	Separators body	PE-HD	D2500,L8820	1				
2	Inlet- outlet pipe	PE-HD	D400mm	1				
3	Inspectionwell 1 (choose the right depth)	PE-HD	D800 mm	1				
	Installation depth h is measured from inlet pipe							
	bottom to groundlevel in mm. On special occasions							
	we can adapt the body for deeper installation)							
4	Inspectionwell 2	PE-HD	D600mm	1				
5	Ventilationpipe	PE-HD	D110 mm					
6	Oil coalescense unit HD Q-PAC							
V	Whole volume	34 750 dm ³						
Vo	Oil layer volume	3 000 dm ³						
Vm	Sand- mud volume	12 500 dm ³						
ADDI [*]	ADDITIONAL EQUIPEMENT (Make Your choise)							
7	Telescopic cover D600 mm			•				
8	Oilseparator alarmunit		·					
	Automatic closing valve							

Please send the completed form by e-mail

Please check your selections and measurements before sending

	Engin	Signature	Sheets	OILSEPARATOR I class EQ-SM NS125 with sand-mud separation		
eccua		Mass		Number		RV