









I'd like to order

I'd like a quote

Mark the installation depth of the tank h (depth from the ground to the bottom of the inlet pipe in mm) h =

Notes (name of project or address, special need etz):

No	NAME	MATERIAL	SIZE	Qn/pcs			
1	Separators body	PE-HD	D1800.L5800	1			
2	Inlet- outlet pipe	PE-HD	PE-HD D315mm				
	Inspectionwell 1 (choose the right depth)	PE-HD	1				
	Installation depth h is measured from inlet pipe						
	bottom to groundlevel in mm. On special occasions						
	we can adapt the body for deeper installation)						
4	Inspectionwell 2	PE-HD	D600mm	1			
5	Ventilationpipe	PE-HD	D110 mm				
6	Oil coalescense unit HD Q-PAC						
V	Whole volume	9950 dm <sup>3</sup>					
Vo	Oil layer volume	1350 dm <sup>3</sup>					
	Sand- mud volume	4000 dm <sup>3</sup>					
ADDI	ADDITIONAL EQUIPEMENT (Make Your choise)						
7	Telescopic cover D600 mm						
8	Oilseparator alarmunit		·				
	Automatic closing valve		·				

Please send the completed form by e-mail

Please check your selections and measurements before sending

				OILSEPARATOR I class EQ-SM NS40		
Date	Engin	Signature	Sheets	with sand-mud separation		
<u>ecci</u>	Ja	Ma	ass	Number	RV	