






I'd like to order

I'd like a quote

Mark the installation depth of the tank h (depth from the ground to the bottom of the inlet pipe in mm) h =

Notes (name of project or address, special need etz):

No	NAME	MATERIAL	SIZE	Qn/pcs			
1	Separators body	PE-HD	D2000,L7930	1			
2	Inlet- outlet pipe	PE-HD	D315mm	1			
3	Inspectionwell 1 (choose the right depth)	PE-HD	D800 mm	1			
	Installation depth h is measured from inlet pipe						
	bottom to groundlevel in mm. On special occasions						
	we can adapt the body for deeper installation)						
4	Inspectionwell 2	PE-HD	D600mm	1			
5	Ventilationpipe	PE-HD	D110 mm				
6	Oil coalescense unit HD Q-PAC						
V	Whole volume	18 120 dm <sup>3</sup>					
Vo	Oil layer volume	1960 dm <sup>3</sup>					
Vm	Sand- mud volume	6500 dm <sup>3</sup>					
ADDITIONAL EQUIPEMENT (Make Your choise)							
7	Telescopic cover D600 mm						
8	Oilseparator alarmunit						
	Automatic closing valve						
	·	•					



Please check your selections and measurements before sending

				OILSEPARATOR I class EQ-SM NS65		
Engi	jin	Signature	Sheets	with sand-mud separation		
eccua		ass	Number		RV	

All rights reserved to Eccua Pro OÜ

